



## KTA-TATOR, INC.

115 Technology Drive, Pittsburgh, PA 15275

(412) 788-1300  
TWX 510 697 3335  
FAX (412) 788-1306

PROTECTIVE COATINGS (PAINT) CONSULTANTS: Testing • Instruments • Inspection • Analytical Laboratory

July 8, 1992


SUBJECT: Testing of Sealmark Textured Coating

Impact resistance was performed by applying the Sealmark Textured Coating to steel Q-panels, and testing in accordance with ASTM D-2794. The Sealmark Textured Coating passed 160 in-lbs with no cracking or disbonding.

Should you have any further questions or comments, please do not hesitate to contact this office.

Very truly yours,

KTA-TATOR, INC.



Dwight G. Weldon

DGW/RNR:wc

JN L4222